

CIRCUIT IDENTIFICATION IS

SWITCHED PER 2006 INTERNATIONAL ENERGY CONSERVATION CODE)

EMERGENCY FEATURE, UP 84" A.F.F., PHOTO-CELL CONTROLLED,

& 1/2" PLASTIC CONDUIT TO ABOVE CEILING (EQUIPMENT ON SITE

1/2" PLASTIC CONDUIT TO ABOVE CEILING (EQUIPMENT ON SITE BY

CEILING MOUNTED SMOKE DETECTOR (EQUIPMENT ON SITE BY OTHERS)

CEILING MOUNTED STROBE LIGHT (EQUIPMENT ON SITE BY OTHERS)

CEILING MOUNTED SPEAKER/STROBE (EQUIPMENT ON SITE BY OTHERS)

- 2. ALL WIRING TO BE PER 2005 N.E.C., W/TYPE ROMEX OR MC WHERE
- 3. MAIN PANEL TO BE MARKED "SUITABLE FOR USE AS SERVICE EQUIPMENT". AND BE EQUIPPED WITH BREAKER/FUSE TYPE OVER CURRENT PROTECTION.

- SERVICE CONNECTED AHEAD OF, BUT NOT WITHIN MAIN SERVICE DISCONNECTING MEANS ENCLOSURE, AND INSTALLED AS PER SERVICE REQUIREMENTS, OR BE
- SHALL BE INSTALLED IN ACCORDANCE WITH ARTICLE 230.06, 2005 N.E.C. 12. EXTERIOR LIGHTS ARE TO BE PHOTO-CELL CONTROLLED AND BI-LEVEL SWITCHING OF INTERIOR LIGHTS IN ACCORDANCE WITH INTERNATIONAL ENERGY CONSERVATION CODE.

## MOBILE MODULAR

P.O. BOX 1099 EDGEWOOD, MD 21040 1-410-676-3700 WWW.MOBILEMODULAR.COM

Mobile/Modular

64 HESS ROAD **LEOLA, PA 17450** PHONE: (717) 656-2081 FAX: (717) 656-4349

## OFFICE MODULAR UNIT FO6064 S BUSINES

**ELECTRICAL PLAN** 

DWG. NO.:	DATE	12-4-08	12-15-08	
DESIGNED: 10/2/08 PRINTED: 6/18/12 11:59AM	REVISIONS	NO	E ALARM	
SERIAL NO.: 08102363-67  SCALE: NTS		NTA REVISION	ADDED FIRE	